

Reg No. 37
2016

Kathmandu Metropolitan City Office

Ward Office No. 5
2052 B.S. (1995 A.D.)

Letter Number:- Ward No. 5/2072/073

Date:- 2072/09/20 B.S.

Dispatch Number:- 545

(January 4, 2016 A.D.)

Subject:- Recommendation


To Whom It May Concern.

According to an application submitted to this office by Euro School, which has been running under the area of Kathmandu Metropolitan City Ward No. 5, seeking recommendation that the school's buildings are safe from fire; while making inquiry according to an application, the content of the application is found to be reasonable. Now, therefore, it is hereby recommended that the school's buildings are safe from fire.

Sd.

2072/9/20 B.S. (January 4, 2016 A.D.)

Om Prakash Poudel
Administrative Chief
Office of Ward No. 5



Post Box No. 8416, Bagdarbar, Kathmandu, Nepal Phone No: 4231481 Fax: 977-1-4268509

Email: kmcmayor@mos.com.np Website: www.kathmandu.gov.np



FIRST AID NEPAL PVT. LTD.

Address: Hanumansthan-10, Kupondole, Lalitpur, Nepal, Tel: +977-01-5905833, 5905834, 9860701963
Email: spoudel509@gmail.com, info@firstaidnepal.com.np
Web: www.firstaidnepal.com.np

Date: 29th /03/2024

To whom it may concern:-

This is to certify that the KANEX brand fire extinguishers installed at **M/S Euro School Private Limited** are manufactured by Kanadia Fire Fyter Pvt. Ltd. And supply by above mentioned vendor. The extinguishers are manufactured as per IS: 1583.

The extinguishers installed at the school premises confirm the IS: 15683 standards installed under proper instruction and will work for one time use only as per manufacturer.

Desired standard and Location for school:-

- 2KG, 5KG AND 6KG for schools (Different Buildings, Corridors, Washroom areas, Dining and Kitchen areas, Auditorium and playing ground area)
- 9 Kg for Kitchen and Generator area etc.
- Once the extinguishers are used please refill it at the authorized service center of the manufacturer.

The Extinguishers supplied can control the fire ABC Class depending on the material burning and area covered by the fire disaster/flash ignition.

If you have, any queries on above subject please feel free to contact us and we are assuring our best services. At all times. We are looking for your favorable response.

With Best Regards,

First Aid Nepal Pvt. Ltd.

(Director: Surya Poudel Mobile: 9851130594)